



## Varco Pruden Buildings Corrosive Environment Checklist

	YES	NO
1. Has the local environment changed in the past three years relative to possible producers of corrosive chemicals, fumes or ashes? (see item #12)	<input type="checkbox"/>	<input type="checkbox"/>
2. Does plain galvanized material in the local environment which is exposed for three years or less show signs of rust stains?	<input type="checkbox"/>	<input type="checkbox"/>
3. Does plain galvanized material in the local environment which is exposed for four years show rust stains on more than ten percent of area?	<input type="checkbox"/>	<input type="checkbox"/>
4. Does plain galvanized material in the local environment which is exposed for five years or more show rust stains on more than seventy five percent of area?	<input type="checkbox"/>	<input type="checkbox"/>
5. Is the building less than 1000 feet from ocean coast line with surf?	<input type="checkbox"/>	<input type="checkbox"/>
6. Is the building less than 600 feet from large salt water bay or sound?	<input type="checkbox"/>	<input type="checkbox"/>
7. Is the building less than 300 feet from salt water, still-water harbor, bayou, canal, or marsh?	<input type="checkbox"/>	<input type="checkbox"/>
8. Will roof be subject to frequent spray of either salt or fresh water? (Spray from cooling towers, highway or street overpass, etc.)	<input type="checkbox"/>	<input type="checkbox"/>
9. Will the operation proposed in the building create or release corrosive substances that will be able to contact either inside or outside of the roof or wall?	<input type="checkbox"/>	<input type="checkbox"/>
10. Will the operations proposed in the building create a very high humidity (over 50% RH)?	<input type="checkbox"/>	<input type="checkbox"/>
11. Will the building house livestock on a regular basis?	<input type="checkbox"/>	<input type="checkbox"/>
12. Are there existing operations within a half mile radius of the proposed site that are possible producers of corrosive chemicals, fumes or ashes?	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Cement Plant		
<input type="checkbox"/> Fertilizer Plant		
<input type="checkbox"/> Plating Works		
<input type="checkbox"/> Chemical Plant		
<input type="checkbox"/> Foundry		
<input type="checkbox"/> Refinery		
<input type="checkbox"/> Concrete Products Plant		
<input type="checkbox"/> Kiln		
<input type="checkbox"/> Steel Mill		
<input type="checkbox"/> Fossil Fuel Power Plant		
<input type="checkbox"/> Paper Mill		
<input type="checkbox"/> Tire Recycle/Manufacture		

A "yes" answer to any of these questions (1 -12) may indicate an exposure area which would be subject to the Corrosive Environment Exclusions in the Varco Pruden Buildings warranties. However, any positive effects of recent local pollution abatement programs should be considered in evaluating the environmental exposure.